



**FIRE DEPARTMENT**  
9 METROTECH CENTER BROOKLYN, N.Y. 11201-3857

Mr. Donald Gottfried, P.E.  
Director of MEA  
NYC Department of Buildings  
280 Broadway, 7<sup>th</sup> Floor  
New York NY 10007

March 4, 2004

**Re: MEA #: New**  
**Manufacturer: Fire Fighting Enterprises Ltd.**  
**Product Beam Detectors & accessories**  
**Model # FIRERAY 50 RU, FIRERAY 100RU, LOW LEVEL**  
**F.P. Index # CONTROLLER (LLC)**  
**0402028**


Dear Mr. Gottfried:

We have reviewed the supporting documentation regarding the above referenced MEA application and have no objection to Department of Buildings considering approval of these products for use in New York City under the following condition.

All uses, configurations, arrangements and functions, application and installations shall comply with the provisions of New York City Buildings Code, specifically Subchapter 17, and Reference Standard 17-3. Further, the installation and spacing shall be in accordance with the manufacturer's recommendation, NFPA 72 and UL standard. Periodic maintenance and sensitivity tests where required shall be conducted in accordance with the regulations of Fire Department.

When responding to this Department regarding this subject matter, kindly refer to F.P. Index #0402028 and address all correspondence to the attention of Mr. Shaji Joseph telephone (718) 999-1514.

Very truly yours,

  
Anthony Hsieh  
Senior Project Manager  
Technology Management

AH:SJ/0402028

C: Mr. Don Campbell  
Design Engineer  
Fire Fighting Enterprises Ltd.  
5, Wedgwood Court  
Stevenage, Herts  
England SGI 4QR