

DECLARATION OF PERFORMANCE

According to Construction Products Regulation 2020, UK Statutory Instruments
2020 No.1359 of Ministry of Housing, Communities and Local Government

No. UKCA-F00



1. Unique identification code of the product-type:

Model Number	Description
16581	Talentum Conventional IR2
16511	Talentum Conventional IR2 Exd
16571	Talentum Conventional IR2 IS
16589	Talentum Conventional IR3
16519	Talentum Conventional IR3 Exd
16579	Talentum Conventional IR3 IS
16591	Talentum Conventional UV/IR2
16521	Talentum Conventional UV/IR2 Exd

Approved Accessories:

07127 Adjustable Mounting Bracket

2. Intended use/es:

Fire safety

3. Manufacturer:

FFE Ltd, 9 Hunting Gate, Hitchin, Hertfordshire, SG4 0TJ, United Kingdom

4. Authorised representative:

FFE B.V., J. Keplerweg 10S, 2408 AC, Alphen aan den Rijn, Netherlands

Note: FFE B.V. has, by issue of written mandate, been authorised by FFE Ltd to act as an Importer for these products, and to carry out the duties required of an Importer within the European Union.

5. System/s of AVCP:

System 1

6. Harmonised standard:

EN 54-10: 2002 + A1: 2005

Notified body/ies:

BRE Global Limited (Notified Body 0832)

Model Number	Description	Certificate Number
16581	Talentum Conventional IR2	0832-UKCA-CPR-F0998
16511	Talentum Conventional IR2 Exd	0832-UKCA-CPR-F0993
16571	Talentum Conventional IR2 IS	0832-UKCA-CPR-F0996
16589	Talentum Conventional IR3	0832-UKCA-CPR-F0999
16519	Talentum Conventional IR3 Exd	0832-UKCA-CPR-F0994
16579	Talentum Conventional IR3 IS	0832-UKCA-CPR-F0997
16591	Talentum Conventional UV/IR2	0832-UKCA-CPR-F1000
16521	Talentum Conventional UV/IR2 Exd	0832-UKCA-CPR-F0995

DECLARATION OF PERFORMANCE

According to Construction Products Regulation 2020, UK Statutory Instruments
2020 No.1359 of Ministry of Housing, Communities and Local Government

No. UKCA-F00



7. Declared performance/s:

Essential Characteristics	EN 54-10: 2002 + A1: 2005	Performance
Nominal activation conditions / Sensitivity, Response delay (response time) and Performance under fire conditions	4.2, 5.2 to 5.6	Pass
Operational reliability	4.3 to 4.9	Pass
Tolerance to supply voltage	5.16	Pass
Durability of operational reliability and response delay; temperature resistance	5.7, 5.8	Pass
Durability of operational reliability; vibration resistance	5.12 to 5.15	Pass
Durability of operational reliability; humidity resistance	5.9, 5.10	Pass
Durability of operational reliability; corrosion resistance	5.11	Pass
Durability of operational reliability; electrical stability	5.17	Pass

The performance of the product/s identified above is in conformity with the set of declared performance/s. This declaration of performance is issued, in accordance with Construction Products Regulation 2020, UK Statutory Instruments 2020 No.1359 of Ministry of Housing, Communities and Local Government, under the sole responsibility of the manufacturer identified above.

Signed for and on behalf of the manufacturer by:

A handwritten signature in black ink, appearing to read 'Steve Revill'.

Steve Revill
Technical Director
Hitchin, 25/01/2024