

## Certificate of Product Approval

Certificate Number: 1204a

Issue: 05

### FFE Ltd

9 Hunting Gate  
Wilbury Way  
Hitchin  
Hertfordshire  
SG4 0TJ  
United Kingdom



is certified by BRE Global Ltd. and is authorised to use the LPCB mark in association with the product(s) listed in this certificate and appendix having complied with the requirement(s) of the standards as detailed below:

### Products

#### Flame Detectors

16511  
16519  
16521  
16571  
16579  
16581  
16589  
16591

(refer to Appendix for details)

### Standards

EN 54-10:2002 + A1:2005

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.

Signed for BRE Global Ltd

P Halligan

Verifier

10 October 2022

Date of Issue

26 June 2014

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a Registered Trademark of the Building Research Establishment Ltd.



## Appendix to Certificate No: 1204a

Issue: 05

### FFE Ltd

Certified Product	Description	LPCB Ref.No.
16511	Talentum Conventional IR <sup>2</sup> (Exd) Flameproof Flame Detector (07127 Bracket) Note: Meets EN 54-10:2002 at Class 1 only	1204a/05
16519	Talentum Conventional IR <sup>3</sup> (Exd) Flameproof Flame Detector (07127 Bracket) Note: Meets EN 54-10:2002 at Class 1 only	1204a/06
16521	Talentum Conventional UV/IR <sup>2</sup> (Exd) Flameproof Flame Detector (07127 Bracket) Note: Meets EN 54-10:2002 at Class 1 only	1204a/07
16571	Talentum Conventional IR <sup>2</sup> Intrinsically Safe Flame Detector (07127 Bracket) Note: Meets EN 54-10:2002 at Class 1 only	1204a/08
16579	Talentum Conventional IR <sup>3</sup> (IS) Intrinsically Safe Flame Detector (07127 Bracket) Note: Meets EN 54-10:2002 at Class 1 only	1204a/09
16581	Talentum Conventional IR <sup>2</sup> Flame Detector (07127 Bracket) Note: Meets EN 54-10:2002 at Class 1 only	1204a/10
16589	Talentum Conventional IR <sup>3</sup> Flame Detector (07127 Bracket) Note: Meets EN 54-10:2002 at Class 1 only	1204a/11
16591	Talentum Conventional UV/IR <sup>2</sup> Flame Detector (07127 Bracket) Note: Meets EN 54-10:2002 at Class 1 only	1204a/12

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan  
Verifier

10 October 2022  
Date of Issue

26 June 2014  
Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a Registered Trademark of the Building Research Establishment Ltd.




## Appendix to Certificate No: 1204a

Issue: 05

### FFE Ltd

#### Ancillaries

07127 Adjustable Mounting Bracket

This Certificate is maintained and held in force through regular surveillance activities and subject to the corresponding ISO 9001 Certificate being maintained.



Signed for BRE Global Ltd

P Halligan

Verifier

10 October 2022

Date of Issue

26 June 2014

Date of First Issue



This certificate and appendix remains the property of BRE Global Ltd. and is issued subject to terms and conditions (for details visit [www.redbooklive.com/terms](http://www.redbooklive.com/terms)).

To check the validity of this certificate and appendix please visit [www.redbooklive.com/check](http://www.redbooklive.com/check), scan the QR tag or contact us.

BRE Global Ltd, Watford, WD25 9XX  
T: +44 (0)333 321 8811 E: [enquiries@breglobal.com](mailto:enquiries@breglobal.com)

LPCB is a Registered Trademark of the Building Research Establishment Ltd.

The logo for BRE (Building Research Establishment), consisting of the lowercase letters 'bre' in a bold, sans-serif font.